

**875—95.12(89) Galvanized pipes, valves, and fittings.** On water heaters without an ASME stamp, galvanized pipes, valves, and fittings may be used on water applications, provided that a dielectric union is also installed in direct contact with dissimilar metals.